

Analytical Report 226244



Laboratory Services

Issue Date: 4/07/2020
Issued By : Sydney Water Laboratory Services

Delivery Address: Sydney Water Corporation
51 Hermitage Rd
West Ryde NSW 2114

Analysis contact: Tel : (02) 9800 6935
Email: analyticalservices@sydneywater.com.au

Attention: Victor Papierniak-Wojtowicz
Customer: Cobar Shire Council
Customer ID: ZCSC

Address: PO Box 223
Cobar NSW 2835
Telephone: 6835 5800

Email: victor.papierniak@cobar.nsw.gov.au

CONTENTS

1. Sydney Water Approved Signatory
2. Sample Summary
3. Analytical results
4. Comments
5. Laboratory QC results

Sydney Water Approved Signatory

Jeya Gajendran, Clean & Waste Water Analyst
Renuka Kasthuriarachchi, Nutrients Analyst

Xin Ren, Microbiology Analyst



Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.

Corporate Accreditation No 63

Accredited for compliance with ISO/IEC 17025 - Testing

SAMPLE SUMMARY

<u>Client Sample ID</u>	<u>Sample Number</u>	<u>Sampling Procedure</u>	<u>Date Sampled</u>	<u>Date Received</u>	<u>Date Authorised</u>	<u>Description</u>
Point 1	L20051970	1	23/06/2020	24/06/2020	03/07/2020	Polisher
Point 2	L20051971	1	23/06/2020	24/06/2020	03/07/2020	Turkeys
Splitter Box 1	L20051972	1	23/06/2020	24/06/2020	30/06/2020	
Splitter Box 2	L20051973	1	23/06/2020	24/06/2020	30/06/2020	
Inlet	L20051974	1	23/06/2020	24/06/2020	30/06/2020	

Sampling procedures

- 1 Samples analysed as received.
- 2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
- 3 Samples collected as per FS procedures SAWI 070.
- 4 Results reported as received from WNSW.

ANALYTICAL RESULTS

Client Sample ID		Point 1	Point 2	Splitter Box 1	Splitter Box 2	Inlet			
Sampled Date		23/06/2020 07:40:00 AM	23/06/2020 07:50:00 AM	23/06/2020 08:00:00 AM	23/06/2020 08:00:00 AM	23/06/2020 08:00:00 AM			
Sample Number		L20051970	L20051971	L20051972	L20051973	L20051974			
CHEMISTRY									
WC12MET : Conductivity									
Conductivity (mS/m)	mS/m	110.1	124.0	-	-	-			
Date of Performance	DD/MM/YY	24/06/20	24/06/20						
WC17NS : Biological oxygen demand									
BOD5	mg/L	<2	<2	260	16	99			
Date of Performance	DD/MM/YY	25/06/20	25/06/20	25/06/20	25/06/20	25/06/20			
WC26NS500 : Grease									
Oil & Grease	mg/L	<5	<5	-	-	-			
Date of Performance	DD/MM/YY	27/06/20	27/06/20						
WC44NS : Determination of Total, Fixed & Volatile Suspended Solids									
Total Suspended Solids	mg/L	10	4	-	-	-			
Date of Performance	DD/MM/YY	26/06/20	26/06/20						
MICRO									

"-" = Not required or refer to Laboratory comment

Client Sample ID		Point 1	Point 2	Splitter Box 1	Splitter Box 2	Inlet			
Sampled Date		23/06/2020 07:40:00 AM	23/06/2020 07:50:00 AM	23/06/2020 08:00:00 AM	23/06/2020 08:00:00 AM	23/06/2020 08:00:00 AM			
Sample Number		L20051970	L20051971	L20051972	L20051973	L20051974			
MICRO									
MI01MUG : Faecal Coliform and/or E. coli									
E.coli	CFU/100mL	-	8	-	-	-			
Faecal Coliform	CFU/100mL	-	8	-	-	-			
Date of Performance	D/M/Y H:M		24/06/20 15:05						
NUTRIENTS									
NU102 : Nitrogen & Phosphorus									
Total Nitrogen	mg/L	7.85	7.69	-	-	-			
Total Phosphorus	mg/L	1.10	0.780	-	-	-			
Date of Performance	DD/MM/YY	26/06/20	26/06/20						

COMMENTS

<u>Sample ID</u>	<u>Comment Level</u>	<u>Method</u>	<u>Test</u>	<u>Comment</u>
L20051971	Method	MI01MUG	-	Result confirmed. Sample analysed outside recommended holding time of 24Hrs.

Analysis

MI01MUG

Analysis Requirements

Faecal Coliforms and/or E.Coli: all results are presumptive unless indicated otherwise.

"-" = Not required or refer to Laboratory comment

LABORATORY QC RESULTS

N/A - Not Applicable

PQL - Practical Quantitation Limit

LOQ - Limit of Quantification

RPD - Relative Percent Difference

SPIKE/Positive Control - Addition of a known amount and concentration

Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1

Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1

Duplicate Precision = Not calculated - Result is outside test range

LOQ	Blank	Positive Control <i>Acceptance Criteria</i>	Negative Control <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	Precision <i>Acceptance Criteria</i>
MI01MUG [Membrane Filtration]E.coli						
<1 CFU/100mL	<1	Accepted	Accepted	8	5	46.15 %
MI01MUG [Membrane Filtration]Faecal Coliform						
<1 CFU/100mL	<1	Accepted	Accepted	8	5	46.15 %

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
NU102 Total Nitrogen						
<0.05 mg/L	<0.05	0.91 <i>0.88 - 1.12 mg/L</i>	102 % Recovery <i>80 - 120 % Recovery</i>	0.30	0.29	B <i>0 - 0 %</i>
NU102 Total Phosphorus						
<0.002 mg/L	<0.002	0.049 <i>0.045 - 0.055 mg/L</i>	94 % Recovery <i>80 - 120 % Recovery</i>	0.003	0.003	B <i>0 - 0 %</i>
WC12MET Conductivity (mS/m)						
<0.1 mS/m	F	140.7 <i>139.3 - 143.3 mS/m</i>	E	121.8	122.2	0.33 % <i>0 - 20 %</i>
WC17NS BOD5						
<2 mg/L	<2	200 <i>139 - 257 mg/L</i>	E			

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
WC26NS500 Oil & Grease						
<5 mg/L	<5	91 85.1 - 101.5 mg/L	E	<5	<5	B 0 - 0 %
WC44NS Total Suspended Solids						
<2 mg/L	<2	52 42.5 - 57.5 mg/L	E	290	310	6.67 % 0 - 20 %

Extra Note:

F: Blank is not applicable for this analyte

E: Spike is not applicable for this analyte

DUPLICATE Total Phosphorus B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Oil & Grease B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ