

# Corporate Accreditation No 63 Accredited for compliance with ISO/IEC 17025 - Testing



**Delivery Address:** Sydney Water Corporation

PO Box 223, Cobar NSW 2835

victor.papierniak@cobar.nsw.gov.au

51 Hermitage Rd

West Ryde NSW 2114

**Telephone:** (02) 9800 6935

6836 5800

Address:

Telephone:

**Email:** analyticalservices@sydneywater.com.au

Analytical Report 288184

Issue Date: 20/07/2023

Issued By: Sydney Water Laboratory Services

Attention: Victor Papierniak-Wojtowicz

Customer: Cobar Shire Council

Customer ID: ZCSC Email:

**CONTENTS** 

1. Sydney Water Approved Signatory

- 2. Sample Summary
- 3. Analytical results
- 4. Comments
- 5. Laboratory QC results

# **Sydney Water Approved Signatory**

Greta Haddad, Nutrients Laboratory Supervisor

Dwijal Dave, Clean & Waste Water Analyst Jeya Gajendran, Clean & Waste Water Analyst

Melissa Wilding, Microbiology Analyst

Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.



# **SAMPLE SUMMARY**

<u>Client</u> <u>Sample ID</u>	<u>Sample</u> <u>Number</u>	Sampling Procedure	<u>Date</u> Sampled	<u>Date</u> <u>Received</u>	<u>Date</u> <u>Authorised</u>	<u>Description</u>
POINT 1	L23057960	1	12/07/2023	13/07/2023	19/07/2023	POLISHER COBAR STP (WASTEWATER)
POINT 2	L23057961	1	12/07/2023	13/07/2023	19/07/2023	TURKEYS COBAR STP (WASTEWATER)
SPITTER BOX 1	L23057962	1	12/07/2023	13/07/2023	19/07/2023	COBAR STP (WASTEWATER)
SPITTER BOX 2	L23057963	1	12/07/2023	13/07/2023	19/07/2023	COBAR STP (WASTEWATER)
S INLET	L23057964	1	12/07/2023	13/07/2023	19/07/2023	COBAR STP (WASTEWATER)

#### **Sampling procedures**

- 1 Samples analysed as received.
- 2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
- 3 Samples collected as per FS procedures SAWI 070.
- 4 Results reported as received from WNSW.



# **ANALYTICAL RESULTS**

		г г							
Client Sample ID		POINT 1	POINT 2	SPITTER BOX 1	SPITTER BOX 2	S INLET			
Sampled Date		12/07/2023 12:00:00 AM							
Sample Number		L23057960	L23057961	L23057962	L23057963	L23057964			
CHEMISTRY	CHEMISTRY								
WC12MET : Conductivity									
	T								I
Conductivity (mS/m)	mS/m	105.9	105.7	-	-	-			
Date of Performance	DD/MM/YY	14/07/23	14/07/23						
WC17NS : Biochemical oxyge	n demand								
	_								
BOD5	mg/L	5	6	200	53	150			
Date of Performance	DD/MM/YY	14/07/23	14/07/23	14/07/23	14/07/23	14/07/23			
WC26NS500 : Oil & Grease									
Oil & Grease	mg/L	<5	<5	-	-	-			
Date of Performance	DD/MM/YY	18/07/23	18/07/23						
WC44NS : Total, Fixed & Vola	tile Suspende	d Solids							
Total Suspended Solids	mg/L	10	10	-	-	-			
Date of Performance	DD/MM/YY	17/07/23	17/07/23						
MICRO									
-									

<sup>&</sup>quot;-" = Not required or refer to Laboratory comment



Client Sample ID		POINT 1	POINT 2	SPITTER BOX 1	SPITTER BOX 2	S INLET		
Sampled Date		12/07/2023 12:00:00 AM						
Sample Number		L23057960	L23057961	L23057962	L23057963	L23057964		
MICRO								
MI01 : Faecal Coliform and/or	E. coli							
E.coli	CFU/100mL	-	5	-	-	-		
Faecal Coliform	CFU/100mL	-	5	-	-	1		
Date of Performance	D/M/Y H:M		13/07/23 15:13					
NUTRIENTS								
NU102 : Total Nitrogen & Total	l Phosphorus							
Total Nitrogen	mg/L	7.70	6.32	-	-	-		
Total Phosphorus	mg/L	2.65	2.51	-	-	-		
Date of Performance	DD/MM/YY	14/07/23	14/07/23					

# **COMMENTS**

Sample ID Comment Level Method Test Comment
L23057961 Method MI01 - Result confirmed. Sample processed outside of holding time, result may be affected.

Analysis Requirements

MI01 Faecal Coliforms and/or E.Coli: all results are presumptive unless indicated

otherwise.

<sup>&</sup>quot;-" = Not required or refer to Laboratory comment



# **LABORATORY QC RESULTS**

N/A - Not Applicable

PQL - Practical Quantitation Limit LOQ - Limit of Quantification RPD - Relative Percent Difference

CRUCE CONTROL OF THE CONTROL OF THE

SPIKE/Positive Control - Addition of a known amount and concentration

Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1

Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1

Duplicate Precision = Not calculated - Result is outside test range



	LOQ	Blank	Positive Control	Negative Control	Duplicate1 Duplicate2		Precision	
			Acceptance Criteria	Acceptance Criteria			Acceptance Criteria	
MI01	[Membrane Filtration]E.col	I						
	<1 CFU/100mL	<1	Accepted	Accepted	5	5	Accepted	
MI01	II01 [Membrane Filtration]Faecal Coliform							
	<1 CFU/100mL	<1	Accepted	Accepted	5	5	Accepted	

LOQ	Blank	Control	Spike	Duplicate1	Duplicate2	RPD
		Acceptance Criteria	Acceptance Criteria			Acceptance Criteria
NU102 Total Nitrogen						
<0.05 mg/L	<0.05	0.91	89 % Recovery	1.17	1.12	4.37 %
		0.88 - 1.12 mg/L	80.0 - 120.0 % Recovery			0.0 - 20.0 %
NU102 Total Phosphorus						
<0.002 mg/L	<0.002	0.049	102 % Recovery	0.029	0.030	3.39 %
		0.045 - 0.055 mg/L	80.0 - 120.0 % Recovery			0.0 - 50.0 %
WC12MET Conductivity (mS/	m)					
<0.1 mS/m	F	140.8	E	38.2	37.6	1.58 %
		139.3 - 143.3 mS/m				0.0 - 20.0 %
WC17NS BOD5						
<2 mg/L	<2	190	E	3	3	В
		139.0 - 257.0 mg/L				0.0 - 0.0 %



LOQ	Blank	Control	Spike	Duplicate1	Duplicate2	RPD
		Acceptance Criteria Acceptance Criteria				Acceptance Criteria
WC26NS500 Oil & Grease						
<5 mg/L	<5	92	E			
		85.1 - 101.5 mg/L				
WC44NS Total Suspended So	olids					
<2 mg/L	<2	54	E	10	9	В
		42.5 - 57.5 mg/L				0.0 - 0.0 %

#### Extra Note:

F: Blank is not applicable for this analyte

E: Spike is not applicable for this analyte

DUPLICATE BOD5 B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

DUPLICATE Total Suspended Solids B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ